

ENERGY AUDIT REPORT

of

ASM's INSTITUTE OF PROFESSIONAL STUDIES,

Pimpri, Pune 411 018



Year: 2021-22

Prepared by

ENGRESS SERVICES

Yashashree, 26, Nirmal Bag Society

Near Muktagan English School, Parvati, Pune 411009

Phone: 09890444795 Email: engress123@gmail.com



MAHARASHTRA ENERGY DEVELOPMENT AGENCY



Maharashtra Energy Development Agency

(Government of Maharashtra Institution)

Aundh Road, Opposite Spicer College Road, Near Commissionerate of Animal Husbandary,

Aundh, Pune, Maharashtra 411067

Ph No: 020-35000450

Email: eee@mahaurja.com, Web: www.mahaurja.com

ECN/2022-23/CR-43/1709


10th May, 2022

**CERTIFICATE OF REGISTRATION
FOR CLASS 'A'**

We hereby certify that, the firm having following particulars is registered with **MAHARASHTRA ENERGY DEVELOPMENT AGENCY (MEDA)** under given category as "Energy Planner & Energy Auditor" in Maharashtra for Energy Conservation Programme of MEDA.

- Name and Address of the firm** : M/s Engress Services
Yashshree, 26, Nirmal Bag Society,
Near Muktangan English School,
Parvati, Pune - 411 009.
- Registration Category** : *Empanelled Consultant for Energy Conservation Programme for Class 'A'*
- Registration Number** : *MEDA/ECN/2022-23/Class A/EA-32.*

- Energy Conservation Programme intends to identify areas where wasteful use of energy occurs and to evaluate the scope for Energy Conservation and take concrete steps to achieve the evaluated energy savings.
- MEDA reserves the right to visit at any time without giving prior information to verify quarterly activities performed by the firm and canceling the registration, if the information is found incorrect.
- This empanelment is valid till 09th May, 2024 from the date of registration, to carry out energy audits under the Energy Conservation Programme
- The Director General, MEDA reserves the right to cancel the registration at any time without assigning any reasons thereof.


General Manager (EC)



ENGRESS SERVICES

Yashashree, 26, Nirmal Bag Society,
Near Mukhtangan English School, Parvati, Pune 411 009
Tel: 020-24220747 Email: engress123@gmail.com

Ref: ES/ASMIPS/21-22/01

Date: 23/6/2022

CERTIFICATE


This is to certify that we have conducted Energy Audit at ASM's Institute of Professional Studies, Pimpri, Pune 411 018 in the year 2021-22.

The Institute has adopted Energy Efficient Practices:

- Usage of Energy Efficient LED Fittings
- Usage of BEE Star Rated Equipment
- In process installation of 2.5 kWp Roof Top Solar PV Plant

We appreciate the support of Management, involvement of faculty members and students in the process of Energy Conservation & making the campus Green.

For Engress Services,



A Y Mehendale,
Certified Energy Auditor
EA-8192



INDEX

| Sr. No | Particulars | Page No |
|--------|--|---------|
| I | Acknowledgement | 5 |
| II | Executive Summary | 6 |
| III | Abbreviations | 7 |
| | | |
| 1 | Introduction | 8 |
| 2 | Study of Connected Load | 9 |
| 3 | Study of Electrical Energy Consumption | 10 |
| 4 | Carbon Foot printing | 12 |
| 5 | Study of Usage of Alternate Energy | 14 |
| 6 | Study of Usage of LED Lights | 15 |



ACKNOWLEDGEMENT

We Engress Services, Pune, express our sincere gratitude to the management of ASM's Institute of Professional Studies, Pimpri, Pune 411 018, for awarding us the assignment of Energy Audit of their Pimpri campus for the Year: 21-22.

We are thankful to all staff members for helping us during the field study.



EXECUTIVE SUMMARY

1. ASM's Institute of Professional Studies, Pimpri, Pune consumes Energy in the form of Electrical Energy; used for various gadgets, Office & other facilities.

2. Energy Consumed & CO₂ Emission:

| No | Parameter | Energy Consumed, kWh | CO ₂ emissions, MT |
|----|-----------|----------------------|-------------------------------|
| 1 | Total | 45345 | 40.81 |
| 2 | Maximum | 4677 | 4.21 |
| 3 | Minimum | 2942 | 2.65 |
| 4 | Average | 3779 | 3.40 |

3. Various Majors Adopted for Energy Conservation:

- Usage of Energy Efficient LED fittings
- Usage of BEE STAR Rated Equipment
- In process installation of 2.5 kWp Roof Top Solar PV Plant.

4. Usage of Alternate Energy Source:

- The Institute is in process of installation of 2.5 kWp Roof Top Solar PV Plant.
- The % of Annual Power requirement met by Alternate Energy is nil

5. Usage of LED Lighting to Total Lighting Load:

- The LED Lighting Load is 4.44 kW.
- The Total Lighting Load is 14.12 kW.
- The percentage of LED Lighting Total Lighting load works out to be 31.44 %

6. Assumption:

- 1 kWh (Unit) of Electrical Energy releases 0.9 Kg of CO₂ into atmosphere

7. Reference:

- For CO₂ Emission Calculations: www.tatapower.com

ABBREVIATIONS

| | |
|--------|--|
| AC | : Air conditioner |
| ASM | : Audyogik Shikshan Mandal |
| BEE | : Bureau of Energy Efficiency |
| CFL | : Compact Fluorescent Lamp |
| FTL | : Fluorescent Tube Light |
| LED | : Light Emitting Diode |
| kWh | : kilo-Watt Hour |
| Qty | : Quantity |
| W | : Watt |
| kW | : Kilo Watt |
| PC | : Personal Computer |
| MT | : Metric Ton |
| MSEDCL | : Maharashtra State Electricity Distribution Company Limited |



CHAPTER-I INTRODUCTION


1.1 Objectives:

1. To study Connected Load and Present Energy Consumption
2. To Study CO₂ emissions
3. To study Scope for usage of Alternate / Renewable Energy
4. To study usage of LED Lighting

1.2 Table No-1: General Details of Institute:

| No | Head | Particulars |
|----|-----------------------|---|
| 1 | Name | ASM's Institute of Professional Studies |
| 2 | Address | Pimpri, Pune 411 018 |
| 3 | Year of Establishment | 2008 |
| 3 | Affiliation | Savitribai Phule Pune University |

1.3 Google Earth Image:



Institute
Campus


CHAPTER-II STUDY OF CONNECTED LOAD

In this chapter, we present the details of various Electrical loads as under

Table No 2: Study of Equipment wise Connected Load:

| No | Equipment | Qty | Load, W/Unit | Load, kW |
|----|------------------|-----|--------------|-----------|
| 1 | 40 W FTL | 230 | 40 | 9.2 |
| 2 | 20 W LED | 40 | 20 | 0.8 |
| 3 | 2*2 40 W LED | 91 | 40 | 3.64 |
| 4 | 45 W CFL Fitting | 10 | 48 | 0.48 |
| 5 | Ceiling fan | 138 | 65 | 8.97 |
| 6 | W/M fan | 4 | 52 | 0.21 |
| 7 | Exhaust Fan | 4 | 36 | 0.14 |
| 8 | AC Load | | 1250 | 18.75 |
| 9 | PC | 47 | 150 | 7.05 |
| 10 | Printer | 4 | 175 | 0.7 |
| 11 | Water Pump | 2 | 2238 | 4.48 |
| 12 | Lift | 1 | 5595 | 5.60 |
| 13 | Other Equipment | 20 | 200 | 4 |
| 13 | Total | | | 64 |

Chart No 1: Details of Connected Load:



CHAPTER-III

STUDY OF PRESENT ENERGY CONSUMPTION

In this chapter, we present the analysis of last year Electricity Energy Consumed
 Table No 3: Electrical Energy Consumed: 21-22:

| No | Month | Energy Consumed, kWh |
|----|---------|----------------------|
| 1 | Apr-21 | 3109 |
| 2 | May-21 | 2942 |
| 3 | Jun-21 | 3544 |
| 4 | Jul-21 | 4159 |
| 5 | Aug-21 | 3292 |
| 6 | Sep-21 | 3401 |
| 7 | Oct-21 | 4137 |
| 8 | Nov-21 | 3992 |
| 9 | Dec-21 | 4677 |
| 10 | Jan-22 | 4490 |
| 11 | Feb-22 | 3782 |
| 12 | Mar-22 | 3820 |
| 13 | Total | 45345 |
| 14 | Maximum | 4677 |
| 15 | Minimum | 2942 |
| 16 | Average | 3779 |

Chart No 2: To study the variation of Month wise Energy Consumed, kWh:




Table No 4: Important parameters:

| No | Parameter | Energy Consumed, kWh |
|----|-----------|----------------------|
| 1 | Total | 45345 |
| 2 | Maximum | 4677 |
| 3 | Minimum | 2942 |
| 4 | Average | 3779 |



CHAPTER-IV CARBON FOOT PRINTING

A Carbon Foot print is defined as the Total Greenhouse Gas emissions, emitted due to various activities.

In this we compute the emissions of Carbon-Di-Oxide, by usage of the various forms of Energy used by the Institute for performing its day to day activities

The Institute uses Electrical Energy for various Electrical gadgets.

Basis for computation of CO₂ Emissions:

The basis of Calculation for CO₂ emissions due to Electrical Energy are: 1 Unit (kWh) of Electrical Energy releases 0.9 Kg of CO₂ into atmosphere

Based on the above Data we compute the CO₂ emissions which are being released in to the atmosphere by the Institute due to its Day to Day operations

Table No 5: Month wise CO₂ Emissions:

| No | Month | Energy Consumed, kWh | CO ₂ Emissions, MT |
|----|---------|----------------------|-------------------------------|
| 1 | Apr-21 | 3109 | 2.80 |
| 2 | May-21 | 2942 | 2.65 |
| 3 | Jun-21 | 3544 | 3.19 |
| 4 | Jul-21 | 4159 | 3.74 |
| 5 | Aug-21 | 3292 | 2.96 |
| 6 | Sep-21 | 3401 | 3.06 |
| 7 | Oct-21 | 4137 | 3.72 |
| 8 | Nov-21 | 3992 | 3.59 |
| 9 | Dec-21 | 4677 | 4.21 |
| 10 | Jan-22 | 4490 | 4.04 |
| 11 | Feb-22 | 3782 | 3.40 |
| 12 | Mar-22 | 3820 | 3.44 |
| 13 | Total | 45345 | 40.81 |
| 14 | Maximum | 4677 | 4.21 |
| 15 | Minimum | 2942 | 2.65 |
| 16 | Average | 3779 | 3.40 |

Chart No 3: Representation of Month wise CO₂ Emissions:




Table No 6: Key observations:

| No | Parameter | Energy consumed, kWh | CO ₂ Emissions, MT |
|----|-----------|----------------------|-------------------------------|
| 1 | Total | 45345 | 40.81 |
| 2 | Maximum | 4677 | 4.21 |
| 3 | Minimum | 2942 | 2.65 |
| 4 | Average | 3779 | 3.40 |



CHAPTER-V

STUDY OF USAGE OF ALTERNATE ENERGY

The Institute is in process of installation of 2.5 kWp Roof top Solar PV Plant.

As on Date the percentage of Annual Power requirement by Alternate Energy is nil.



CHAPTER-VI

STUDY OF USAGE OF LED LIGHTS

In the following Table, we present the percentage of usage of LED lights to Total Lighting Load.

Table No 7: Study of % LED Lighting Load to Total Lighting Load:

| No | Particulars | Value | Unit |
|----|--|-------|--------|
| 1 | Qty of 40 W FTL Fittings | 230 | Nos |
| 2 | Load per Unit of 40 W FTL Fitting | 40 | W/Unit |
| 3 | Total Load of 40 W FTL Fittings | 9.2 | kW |
| 4 | Qty of 20 W LED Fittings | 40 | Nos |
| 5 | Load per Unit of 20 W LED Fitting | 20 | W/Unit |
| 6 | Total Load of 20 W LED Fittings | 0.8 | kW |
| 7 | Qty of 40 W LED Fittings | 91 | Nos |
| 8 | Load per Unit of 40 W LED Fitting | 40 | W/Unit |
| 9 | Total Load of 40 W LED Fittings | 3.64 | kW |
| 10 | Qty of 45 W CFL Fittings | 10 | Nos |
| 11 | Load per Unit of 45 W CFL Fitting | 48 | W/Unit |
| 12 | Total Load of 45 W CFL Fittings | 0.48 | kW |
| 13 | Total LED Lighting Load =6+9 | 4.44 | kW |
| 14 | Total Lighting Load= 3+6+9+12 | 14.12 | kW |
| 15 | Percentage of LED to Total Lighting Load= $13 \times 100 / 14$ | 31.44 | % |