ENERGY AUDIT REPORT

of

ASM's INSTITUTE OF PROFESSIONAL STUDIES,

Pimpri, Pune 411 018



Year: 2022-23

Prepared by

ENGRESS SERVICES

Yashashree, 26, Nirmal Bag Society
Near Muktangan English School, Parvati, Pune 411009
Phone: 09890444795 Email: engress123@gmail.com



ENGRESS SERVICES

Yashashree, 26, Nirmal Bag Society, Near Muktangan English School, Parvati, Pune 411 009

Tel: 09890444795 Email: engress123@gmail.com MEDA Registration No: ECN/2022-23/CR-43/1709 ISO: 9001-2015 Certified (Cert No: 23EQKC13), ISO: 14001-2015 Certified (Cert No: 23EEKW20)

ENERGY AUDIT CERTIFICATE

Certificate No: ES/ASMIPS /22-23/01 Date: 28/6/2023

This is to certify that we have conducted Energy Audit at ASM's Institute of Professional Studies, Pimpri, Pune 411 018 in the year 2022-23.

The Institute has adopted Energy Efficient Practices:

- Usage of Energy Efficient LED Fittings
- > Usage of BEE Star Rated Equipment
- ➤ The College has installed 2.18 kWp Roof Top Solar PV Plant

We appreciate the support of Management, involvement of faculty members and students in the process of Energy Conservation & making the campus Green.

For Engress Services,

A Y Mehendale,

B E-Mechanical, M Tech- Energy

Amcherd


BEE Certified Energy Auditor, EA-8192

REGISTRATION CERTIFICATES






AUDITOR CERTIFICATE



ISO: 9001-2015 Certificate

MEDA Registration Certificate



ISO: 14001-2015 Certificate



INDEX

Sr. No	Particulars	Page No
I	Acknowledgement	5
11	Executive Summary	6
111	Abbreviations	7 .
1	Introduction	8
2	Study of Connected Load	9
3	Study of Present Energy Consumption	10
4	Study of Energy Performance Index	11
5	Study of Lighting	12
6	Study of Renewable Energy & Energy Efficiency	14

ACKNOWLEDGEMENT

We Engress Services, Pune, express our sincere gratitude to the management of ASM's Institute of Professional Studies, Pimpri, Pune 411 018, for awarding us the assignment of Energy Audit of their Pimpri campus for the Year: 2022-23.

We are thankful to all staff members for helping us during the field study.



EXECUTIVE SUMMARY

1. ASM's Institute of Professional Studies, Pimpri, Pune consumes Energy in the form of Electrical Energy; used for various gadgets, Office & other facilities.

2. Present Connected Load & Energy Consumption:

No	Particulars	Value	Unit
1	Total Connected Load	71.21	kW
2	Annual Energy Purchased	44536	kWh

3. Energy Performance Index:

No	Particulars	Value	Unit
1	Total Annual Energy Purchased	44536	kWh
2	Annual Energy Generated	784.8	kWh
3	Annual Energy Consumed=1+2	45320.8	kWh
4	Total Built up area of Institute	3054.66	m²
5	Energy Performance Index =(3) / (4)	14.84	kWh/m ²

4. Study of % Usage of LED Lighting:

No	Particulars	Value	Unit
1	% of Usage of LED Lighting to Total Lighting Load	31.44	%

5. Renewable Energy & Energy Efficiency Projects:

- Usage of Energy Efficient LED fittings
- Installation of 2.18 kWp Roof Top Solar PV Plant

6. Assumptions:

- 1. 1 kWh of Electrical Energy releases 0.9 Kg of CO₂ into atmosphere
- 2. Energy generated by Roof Top Solar PV Plant: 4 kWh/kWp per Day
- 3. Annual Solar Energy generation Days: 90 Nos

7. References:

- Audit Methodology: www.mahaurja.com
- Energy Conservation Building Code: ECBC-2017: www.beeindia.gov.in
- For CO₂ Emissions: <u>www.tatapower.com</u>
- For Solar PV Energy generation: www.solarrooftop.gov.in



ABBREVIATIONS

AC : Air conditioner

ASM : Audyogik Shikshan Mandal

BEE : Bureau of Energy Efficiency

CFL : Compact Fluorescent Lamp

FTL: Fluorescent Tube Light

LED : Light Emitting Diode

kWh : kilo-Watt Hour

Qty : Quantity

W : Watt

kW : Kilo Watt

PC : Personal Computer

MT : Metric Ton

MSEDCL: Maharashtra State Electricity Distribution Company Limited

CHAPTER-I INTRODUCTION


1.1 Introduction:

An Energy Audit is conducted at ASM's Institute of Professional Studies, Pimpri, Pune


The guidelines followed for conducting the Energy Audit are:

- BEE India's Energy Conservation Building Code: ECBC-2017
- Maharashtra Energy Development Agency (<u>www.mahaurja.com</u>)
- Tata Power: <u>www.tatapower.com</u>

1.2 Audit Procedural Steps:



1.3 Institute Location Image:




CHAPTER-II STUDY OF CONNECTED LOAD

In this chapter, we present the details of various Electrical loads as under

Table No 1: Study of Equipment wise Connected Load:

No	Equipment	Qty	Load, W/Unit	Load, kW
1	40 W FTL	230	40	9.2
2	20 W LED	40	20	0.8
3	2*2 40 W LED	91	40	3.64
4	45 W CFL Fitting	10	48	0.48
5	Ceiling fan	138	65	8.97
6	W/M fan	4	52	0.208
7	Exhaust Fan	4	36	0.144
8	AC Load, in TR		18750	18.75
9	PC	95	150	14.25
10	Printer	4	175	0.7
11	Water Pump	2	2238	4.476
12	Lift	1	5595	5.595
13	Other Equipment	20	200	4
13	Total			71.21

Chart No 1: Details of Connected Load:





Engress Services, Pune


CHAPTER-III STUDY OF PRESENT ENERGY CONSUMPTION

In this chapter, we present the analysis of Electrical Energy Consumption.

Table No 2: Electrical Energy Purchase Analysis- 2022-23:

No	Month	Energy Purchased, kWh	CO ₂ Emissions, MT
1	Jun-22	4506	4.06
2	Jul-22	3913	3.52
3	Aug-22	3587	3.23
4	Sep-22	3497	3.15
5	Oct-22	3255	2.93
6	Nov-22	3352	3.02
7	Dec-22	3614	3.25
8	Jan-23	3536	3.18
9	Feb-23	3553	3.20
10	Mar-23	3977	3.58
11	Apr-23	3859	3.47
12	May-23	3887	3.50
13	Total	44536	40.08
14	Maximum	4506	4.06
15	Minimum	3255	2.93
16	Average	3711	3.34

Chart No 2: Variation in Monthly Energy Purchased, kWh:



ENG CESSION OF STREET

CHAPTER-IV STUDY OF ENERGY PERFORMANCE INDEX

Energy Performance Index: Energy Performance Index of a Building is its Annual Energy Consumption in Kilo Watt Hours per square meter of the Building

It is determined by:

EPI = (<u>Annual Energy Consumption in kWh</u>) (Total Built-up area in m²)

Now we compute the EPI for the Institute as under:

Table No 3: Computation of Energy Performance Index:

No	Particulars	Value	Unit
1	Total Annual Energy Purchased	44536	kWh
2	Energy Generated by Solar PV Plant	784.8	kWh
3	Total Energy Consumed= 1+2	45320.8	kWh
4	Total Built up area of Institute	3054.66	m ²
5	Energy Performance Index =(3) / (4)	14.84	kWh/m²



CHAPTER V STUDY OF LIGHTING

Terminology:

- 1. Lumen is a unit of light flow or luminous flux. The lumen rating of a lamp is a measure of the total light output of the lamp. The most common measurement of light output (or luminous flux) is the lumen. Light sources are labeled with an output rating in lumens.
- **2.** Lux is the metric unit of measure for illuminance of a surface. One lux is equal to one lumen per square meter.
- 3. Circuit Watts is the total power drawn by lamps and ballasts in a lighting circuit under assessment.
- **4.** Installed Load Efficacy is the average maintained illuminance provided on a horizontal working plane per circuit watt with general lighting of an interior. Unit: lux per watt per square metre (lux/W/m²)
- **5. Lamp Circuit Efficacy** is the amount of light (lumens) emitted by a lamp for each watt of power consumed by the lamp circuit, i.e. including control gear losses. This is a more meaningful measure for those lamps that require control gear. Unit: lumens per circuit watt (lm/W)
- 6. Installed Power Density. The installed power density per 100 lux is the power needed per square metre of floor area to achieve 100 lux of average maintained illuminance on a horizontal working plane with general lighting of an interior. Unit: watts per square metre per 100 lux (W/m²/100 lux) 100 Installed power density (W/m²/100 lux)
- **7.** Lighting Power Density: It is defined as Total Lighting Load in a room divided by the Area of that Room in square meters.

In this Chapter we compute the percentage usage of LED Lighting to total Lighting Load of the Institute.

Table No 4: Percentage Usage of LED Lighting to Total Lighting Load:

No	Particulars	Value	Unit
1	Qty of 40 W FTL Fittings	230	Nos
2	Load per Unit of 40 W FTL Fitting	40	W/Unit
3	Total Load of 40 W FTL Fittings	9.2	kW
4	Qty of 20 W LED Fittings	40	Nos
5	Load per Unit of 20 WLED Fitting	20	W/Unit

An Es

6	Total Load of 20 W LED Fittings	0.8	kW
7	Qty of 40 W LED Fittings	91	Nos
8	Load per Unit of 40 WLED Fitting	40	W/Unit
9	Total Load of 40 W LED Fittings	3.64	kW
10	Qty of 45 W CFL Fittings	10	Nos
11	Load per Unit of 45 W CFL Fitting	48	W/Unit
12	Total Load of 45 W CFL Fittings	0.48	kW
13	Total LED Lighting Load =6+9	4.44	kW
14	Total Lighting Load= 3+6+9+12	14.12	kW
15	Percentage of LED to Total Lighting Load=13*100/14	31.44	%

CHAPTER-VI STUDY OF RENEWABLE ENERGY & ENERGY EFFICIENCY

6.1 Usage of Renewable Energy:

The Institute has installed:

• Roof Top Solar PV Plant of Capacity 2.180 kWp

As on Date the percentage of Annual Power requirement by Alternate Energy is nil.



6.2 Energy Efficiency Measures adopted:

- The Institute has Energy Efficient LED Fittings.
- Usage of BEE STAR Rated Equipment

Photographs of STAR Rated AC & LED Lighting:





